

Attestation

LEED v4 and v4.1 BETA

On the 7th of February 2024, Eurofins Product Testing A/S received a sample of a wooden parquet with the product name:

3.Parky Deluxe+, Parky Master+, Parky Summit+, Parky Swing+, Parky Twist+

supplied by

Decospan NV

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, and CDPH 01350 testing standards (See test report no. 392-2024-00076401_H_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED v4.1 BETA (February 2024) projects globally by showing compliance with the specifications for VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:

- The requirements of LEED v4 and LEED v4.1 BETA (February 2024): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017); and a TVOC below 0.5 mg/m³ in both office and class room.

9 April 2024



Henriette Buch Lauersen
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.