



WOOD.BE

Our reference: tw/Decospan200034/2Rp.doc

Report n° 200034/2

Client : Decospan nv
 Lageweg 33
 B-8930 Menen

Object : Determination of the Reaction to Fire

Date: 07/04/2020

This report contains 2 pages and can only be distributed in full by facsimile with the permission of WOOD.BE

Required tests : Determination of the reaction to fire according to EN13501-1 :2019

Results

Decospan reference	WOOD.BE reference	External Lab reference	EN13501:2019
Parky 7.2 mm	AE200102	T2001951	B _{fl} /s1
Parky 8.3 mm	AE200103	T2001950	B _{fl} /s1
Parky 12 mm	AE200104	T2001949	B _{fl} /s1
Parky 10 mm	AE200105	T2001952	B _{fl} /s1

Cfr/ annexes (tests executed in external lab)

- Parky 12 mm : Analysis Report 20.00501.01: 8 pages
- Parky 8.3 mm : Analysis Report 20.00501.02: 8 pages
- Parky 7.2 mm : Analysis Report 20.00501.03: 8 pages
- Parky 10 mm : Analysis Report 20.00501.04: 8 pages

Brussels,
05/10/2020



Ir. Thomas Wynsberghe
RD 'Floor coverings'